

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

To,

Principal
Imperial International School For Excellence, Khuian Sarwar


No.: Abohar/2324/00202 Dated : 29/02/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1091 Dated: 23/02/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/02/2024. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar



Principal
Imperial International
School For Excellence
KHUIAN SARWAR



Manager
Imperial International School
for Excellence, Khuian Sarwar

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

TEST REPORT

Name & Address of Customer : Principal Imperial International School For Excellence, Khuian Sarwar			Customer Reference No. No : 1091 Dated : 23/02/2024			
			Sample Submitted by			
			Date of Sample Receipt 22/02/2024			
			Analysis Starting Date 23/02/2024			
			Analysis completion Date 24/02/2024			
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type : Water			
Test Report No.: Abohar/2324/00202			Date of Issue : 29/02/2024			
Registration no.: Abohar/REG2324/00666			Condition of Sample : Sealed			
Collection Point: Distribution Point(Near Bus stand,School,Gurudwara,etc)			Quantity/Type of Bottle: 1000 ml / Plastic Bottles			
Scheme/Source: Not Mentioned(Not Mentioned)			Location/Depth : Imperial International School for Excellence, Khuian Sarwar / NA			
Village : Khuian Sarwar			Habitation : Khuian Sarwar			
Block: Khuian Sarwar			District : Fazilka			
Latitude : Not Mentioned			Longitude: Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.40	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	210	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	176	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	61	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	124	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Sarwar

Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

Rangan
**Principal
Imperial International
School For Excellence
KHUIAN SARWAR**

End of the Test Report

Sulchana
**Manager
Imperial International School
for Excellence, Khuian Sarwar**