

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 297

Dated: 27/07/24

It is certified that an inspection team headed by Sh. Rattanajot Singh Sub divisional Engineer water Supply & Sanitation Sub div. Khuan Sarwar with Sh. Vinod Kumar JE (Name of Officers with Designation) from PHED inspected the Imperial International School For Excellence, Village: Khuan Sarwar, Tehsil: Abohar, District: Fazilka, State: Punjabon 21-02-2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ABOH92/2324/00202 dated 29/02/2024 of (PHED Lab) certified that the Imperial International School For Excellence has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by Central/ State/U.T. Govt.

The certificate is valid till 31/08/2025

Signature with Seal:

Name: Rattanajot Singh
Designation: SPE

Sub Divisional Engineer,
W/S & Sanitation Sub Division,
Khuan Sarwar

Name and Address of the Office / Department: Sub Divisional Engineer W/S & Sanitation Sub Division Khuan Sarwar

To

Imperial International School For Excellence
Village: Khuan Sarwar
Tehsil: Abohar
District: Fazilka, State: Punjab

Note: The certificate is to be issued by authorized officer / PHED Lab / Local Bodies

Rugam
Principal
Imperial International
School For Excellence
KHUAN SARWAR

Sulchinder H
Manager
Imperial International School
for Excellence, Khuan Sarwar

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

To,

Principal
Imperial International School For Excellence, Khuian Sarwar


No.: Abohar/2324/00202 Dated : 29/02/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 1091 Dated: 23/02/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 22/02/2024. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar



Principal
Imperial International
School For Excellence
KHUIAN SARWAR



Manager
Imperial International School
for Excellence, Khuian Sarwar

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

TEST REPORT

Name & Address of Customer : Principal Imperial International School For Excellence, Khuian Sarwar			Customer Reference No.		No : 1091 Dated : 23/02/2024	
			Sample Submitted by			
			Date of Sample Receipt		22/02/2024	
			Analysis Starting Date		23/02/2024	
			Analysis completion Date		24/02/2024	
Discipline : Chemical Testing			Group: Water			
ULR No.:			Sample Type :		Water	
Test Report No.: Abohar/2324/00202			Date of Issue :		29/02/2024	
Registration no.: Abohar/REG2324/00666			Condition of Sample :		Sealed	
Collection Point: Distribution Point(Near Bus stand,School,Gurudwara,etc)			Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source: Not Mentioned(Not Mentioned)			Location/Depth :		Imperial International School for Excellence, Khuian Sarwar / NA	
Village : Khuian Sarwar			Habitation :		Khuian Sarwar	
Block: Khuian Sarwar			District :		Fazilka	
Latitude : Not Mentioned			Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.40	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	210	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	176	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	61	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	124	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Manju Sarwar

Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

Rangan
**Principal
Imperial International
School For Excellence
KHUIAN SARWAR**

End of the Test Report

Sulchana
**Manager
Imperial International School
for Excellence, Khuian Sarwar**